


## Product Code

# 3185W/9

Right-angle Check Valve

1.1/8" ODS<br>PS = 50 bar - 600 psi



## Product use

Accessories for use with the following ASHRAE 34:2019 refrigerants, Class A1:

HCFC (R22)

HFC (R134a, R404A, R407C, R410A, R507)

HFO (R1234ze)

HFO + HFC (R448A, R449A, R450A, R452A, R513A, R515A, R515B)

## Product Details

**Connections SAE Flare** 1.1/8"

**Connections ODS Ø [in.]** -

**ODS Ø [mm]** -

**Kv [m³/h]** 19

**Differential pressure (2) [bar]** 0,3

**PS [bar]** 50

**MWP [psi] (1)** 600

**TS [°C] Min** -40

**TS [°C] Max** +150

**Package pcs** 1

## Notes where expressly stated

(1): according to UL approval

(2): minimum pressure at which the valve is completely open.