


Product Code

3144W/7

Check Valve

7/8"-22mm ODS
PS = 50 bar - 650 psi



Product use

Accessories for use with the following ASHRAE 34:2019 refrigerants, Class A1, A2L, or A3:
 HFC (R134A, R32, R404A, R407C, R410A, R507)
 HFO (R1234YF, R1234ZE)
 HFO + HFC (R448A, R449A, R450A, R452A, R452B, R454A, R454B, R454C, R455A, R513A, R515A, R515B)
 HC (R290, R600, R600A, R1270)

Product Details

Connections ODS Ø [in.] 7/8"

Connections ODS Ø [mm] -

Kv [m³/h] 8,1

Differential pressure (2) [bar] 0,04

PS [bar] 50

MWP [psi] (1) 650

TS [°C] Min -40

TS [°C] Max +150

Package pcs 15

Notes where expressly stated

(1): according to UL approval

(2): minimum pressure at which the valve is completely open